MOBIAK S.A. is Certified according to the following Quality Management Systems & Maritime Services:

CODE:

ERP: 0142253

Addressable Optic & Accoustic Siren IP42

Sirens with Beacon

Addressable siren unit, it has a sound indicator and a beacon



CHARACTERISTICS	
Code	MBK17-BSR-5032
Operation Voltage	21-28V
Standby Consumption	1 mA
Alarm Consumption	20 mA
Minimum Sound Output (1m)	87dB with jumpers / 78dB without jumpers
Degrees Of Cover Protection	IP 42
Produced In Accordance With	EN 54-3
Operation Temperature Range	-20 to 60ºC
Relative Humidity	Up to 95% relative humidity
Dimensions	140 x 140 x 90 mm
Weight	210gr
Guarantee	2 Years

EN 54-3

Issue Date: 07/07/2023

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644
ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986
NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151
www.mobiakfire.com