MOBIAK S.A. is Certified according to the following Quality Management Systems & Maritime Services:

CODE:

ERP: 0142019

Fire extinquishing manual call poin Conventional

Call Points

Button for activating fire suppression system. It is suitable for indoor use.

These buttons which activate the fire suppression system manually. It is necessary to there in cooperation with detectors.



CHARACTERISTICS	
Code	MBK17-BS-533
Main Voltage	12 -30 V DC
Alarm Current	20 - 30 mA
Degrees Of Cover Protection	IP 20
Produced In Accordance With	EN 12094-3
Operation Temperature Range	0 to 60ºC
Humidity	Up to 65% relative humidity
Color	Yellow
Dimensions	94x90x54mm
Weight	160gr
Guarantee	2 Years

EN 12094-3

CE

Issue Date: 07/07/2023

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644
ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986
NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151
www.mobiakfire.com