MOBIAK S.A. is Certified according to the following Quality Management Systems & Maritime Services:

CODE:

ERP: 0142244

8 Zones Fire Detection Panel with Screen Conventional

Fire Detection Panels

8 Zones Fire Detection Panel with Screen Fire Detection Panels 8 zones fire detection panels with identical operation and indications. Programming and monitoring is done using a graphical display. Fully programmable depending on the requirements of each installation, providing detailed event information in English and Greek Language. They also have events history memory. All panels incorporate 2 outputs for sirens, an alarm relay, a fault relay and an auxiliary relay. Ethernet control and programming capability (card GR-8530).



CHARACTERISTICS	
Code	MBK17-BS1638
Type	Conventional
Zones	8

EN 54-2:1997+A1:2006 EN 54-4:1997+A1:2002+A2:2006

Issue Date: 07/07/2023 Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644
ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986
NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151
www.mobiakfire.com