MOBIAK S.A. is Certified according to the following Quality Management Systems & Maritime Services:

CODE:

ERP: 0142015

16 Zones Fire Detection Panel with Screen Conventional

Fire Detection Panels

16 Zones Fire Detection Panel with Screen Fire Detection Panels 16 zones fire detection panels with identical operation and indications. Programming and monitoring is done using a graphical display. Fully programmable depending on the requirements of each installation, providing detailed event information in English and Greek Language. They also have events history memory. All panels incorporate 2 outputs for sirens, an alarm relay, a fault relay and an auxiliary relay. Ethernet control and programming capability (card GR-8530).



CHARACTERISTICS	
Code	MBK17-BS1646
Type	Conventional
Zones	16

EN 54-2:1997+A1:2006 EN 54-4:1997+A1:2002+A2:2006

Issue Date: 07/07/2023 Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644
ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986
NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151
www.mobiakfire.com