

CODE:

ERP:

0149048

Fire Extinguish Panel with 1 Extinguish Output and 4 Zones Conventional Fire Detection Panels

Fire extinguishing panel, 1 command with 4 zones in Metallic Housing. The panel has: One fire extinguish output monitored for open and short circuit. • The output can operate with actuators or electro valves. • Two cross zones for fire detectors • One zone for a manual call point to start the extinguish procedure • One zone for a manual call point to cancel the extinguish procedure • Three modes of operation • The panel has two independent siren outputs • One contact relay for fault status • Two fully programmable relay contacts • Terminals to communicate with conventional fire detection panels • Battery (12V/7Ah) is required for the operation of the panel (is not included). Devices that can be used by a person to signify a fire alarm. They are required in every fire alarm system. In every fire alarm system a call point is located beside the main fire alarm panel and the rest near stair and exits in well distinct points that are easily accessible by people abandoning the area. A call point used for activating fire extinguishing units and is suitable for interior use. A call point used for activating fire extinguishing units and is suitable for interior use. It has an isolation lock. If the lock's key is placed in the OFF position, the call point event if it is activated, does not activate the fire extinguishing unit.



CHARACTERISTICS

Code	MBK17-BS-627
Type	Conventional
Zones	4

EN 54-2

EN 54-4

EN 12094-1

Issue Date: 07/07/2023

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com