

CODE:

ERP:

0142248

Addressable Fire Detection Control Panel 4 loop / 96 zones

Fire Detection Panels

For compliance with LPCB approval, the maximum number of loops connected must not exceed 4. The panels is designed and constructed according to EN54-2 and EN54-4 regulations. Each loop can accept up-to 150 total points, which can be input units (detectors, call points), output units and line isolators. For compliance with LPCB approval, the maximum number of fire detectors and manual call points connected to a panel must not exceed 512.



CHARACTERISTICS

Code	MBK17-BSR-2114
Τύπος	Addressable
Zones	96
Loop	4

EN 54-2

EN 54-4



Issue Date: 07/07/2023

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com