MOBIAK S.A. is Certified according to the following Quality Management Systems & Maritime Services:

CODE:	MBK17-BSR-6060/A
ERP:	0142251

Analog addressable rate of rise heat detector for Control Panel MBK17-BSR-2104 & MBK17-BSR-2114

Detectors

BSR-6060/A/AR is an analogue addressable detector that combines two heat funcions. Inside it's chamber there are two sensors, one rate of rise and one thermal sensor. BSR-6060/A/MAR is a thermal and rate of rise detector simultaneously. It co-operates exlusively with analoque addressable panels BSR-2104/ MAR / BSR-2114/MAR and is constructed according to EN-54-5, IEC 60092-504, IEC 60533. it also includes a connection bracket.



CHARACTERISTICS	
Operation Voltage	18-30V DC
Idle State Power Consumption	1mA
Alarm Power Consumption	1,5 mA (LED on)
Sensitivity	5 °C / min
Indicators	Activation LED
Class	A2R
Degrees Of Cover Protection	IP 20
Produced In Accordance With	EN 54-5
Operation Temperature Range	-10 to 60ºC
Relative Humidity	Up to 95%
Dimensions	103 (diameter) x 48 (high) mm
Weight	145gr
Guarantee	2 years

EN 54-5

Issue Date: 07/07/2023

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644
ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986
NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151
www.mobiakfire.com