MOBIAK S.A. is Certified according to the following Quality Management Systems & Maritime Services:

CODE:	0142411
ERP:	0142411

Carbon monoxyde Detector

Detectors

Certified Carbon monoxyde Detector for parking.



CHARACTERISTICS	
Power supply	12÷24Vcc (-10/+15%) – 2 W
Output	4÷20mA Linear
Load resistor	100 Ω max
Sensor	Electrochemical
Standard range	0 ÷ 300 ppm (CO)
Sensor limits	1000 ppm
Response time T90	
Resolution	1 ppm of the signal
Accuracy	± 5 % of the signal
Repeatability	± 5% of the signal
Long time drift in pure air	
Expected life in pure air	5 years
Max Storage Time	6 moths
Operation Pressure	Atmospheric ±10%
Operation Temp./Humidity	-20 ÷ +50 °C / 15÷90 % r.h.
Storage Temp./Humidity	-0 ÷ +20°C / 5÷95 % r.h.

Issue Date: 07/07/2023

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644
ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986
NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151
www.mobiakfire.com