
MOBIAK S.A. is Certified according to the following Quality Management Systems & Maritime Services:

CODE:	
ERP:	0142254

Addressable Manual Call Point

Call Points

The product is certified by EVPU. Addressable Manual Call point, when it is activated, informs the board about the exact address of the event and simultaneously lights up the integrated pushbutton LED. It has special switches for address selection.



CHARACTERISTICS	
Code	MBK17-BSR-5036/A
Operation Voltage	21-28V
Standby Consumption	1 mA
Alarm Consumption	20 mA
Type	Type A
Use	Indoor
Degrees Of Cover Protection	IP 20
Produced In Accordance With	EN 54-11
Operation Temperature Range	0 to 60ºC
Relative Humidity	up to 95%
Construction Materials	Bayblend FR3010
Dimensions	98 x 94 x 58 mm
Weight	190 gr
Guarantee	2 Years

EN 54-7 EN 54-11

Issue Date: 07/07/2023

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644
ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986
NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151
www.mobiakfire.com