

CODE:

ERP:

0142021

Fire extinguishing manual call poin with cancellation key Conventional Call Points

Button for activating fire suppression system. It is suitable for indoor use. It has isolation key. If the key is placed in the OFF position by the user, the button even if deceived will not send command to the extinguishing system.

These buttons which activate the fire suppression system manually. It is necessary to there in cooperation with detectors.



CHARACTERISTICS

Code	MBK17-BS-534
Main Voltage	12 -30 V DC
Alarm Current	20 - 30 mA
Degrees Of Cover Protection	IP 20
Produced In Accordance With	EN 12094-3
Operation Temperature Range	0 to 60°C
Humidity	Up to 95% relative humidity
Color	Yellow
Dimensions	94x90x54mm
Weight	160gr
Guarantee	2 years

EN 12094-3



Issue Date: 07/07/2023

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P¹ str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com